




NOTE :

THE GROUND ROD SHALL BE INSTALLED OBLIQUELY THROUGH THE FOUNDATION IN UNDISTURBED SOIL AT AN ANGLE NOT TO EXCEED 45° FROM THE VERTICAL.

METRIC (& ENGLISH) UNITS

		SANTA CLARA COUNTY ROADS AND AIRPORTS DEPARTMENT			STANDARD DETAILS CABINET BONDING/GROUNDING	DRAWING NO. E 48 SHEET NO. 1 of 1						
NO.	REVISIONS	BY	DATE	APP'D	DESIGNED TH 04/15/97	DATE 04/15/97	WORK ORDER	SUBMITTED:	APPROVAL:	PROJECT NO.	CONTRACT NO.	FILE NO.
					DRAWN APK 04/15/97	DATE 04/15/97	LEVEL BOOK					
					CHECKED	DATE	TRANSIT BOOK					