

POST TOP (SEE NOTE 1)

NOTES:

- 1) POST TOP LIGHTING STANDARD SHALL BE USED FOR REPLACEMENT IN KIND OF EXISTING ONLY.
- 2) POLES SHALL BE GALVANIZED STEEL OR ALUMINUM. SHOP DRAWINGS AND SPECIFICATIONS SHALL BE SUBMITTED FOR REVIEW AND ACCEPTANCE PRIOR TO FABRICATION.
- 3) A 5mm (3/16") OR LARGER BRASS OR BRONZE GROUND LUG SHALL BE INSTALLED INSIDE THE POLE OPPOSITE TO THE HANDHOLE OPENING.
- 4) BASE PLATE BOLT CIRCLE SHALL BE AS SPECIFIED ON THE PROJECT PLANS. BOLT HOLES SHALL BE ELONGATED.
- 5) EACH STANDARD SHALL BE FURNISHED WITH A BASE PLATE AND COVER, 8 GALVANIZED NUTS AND 8 GALVANIZED WASHERS.

METRIC (& ENGLISH) UNITS

SANTA CLARA COUNTY ROADS AND AIRPORTS DEPARTMENT STANDARD DETAILS 11/29/10 TONG HONG LIGHTING STANDARD DAN COLLEN 6B 11/29/10 SENIOR CIVIL ENGINEER DEPUTY DIRECTOR TYPE POST TOP No C33113 Exp. 6–30–12 11/29/10 DATE CONTRACT NO. REVISIONS BY DATE